

**EXIT SIGN
EMERGENCY LIGHT FIXTURE
ANNUAL 90 MINUTE TESTING**

The purpose of the test is:

1. To make sure the EXIT signs are illuminated with normal electrical supply.
2. To make sure all fixtures are illuminated during an electrical power failure for 90 minutes using the battery backup supply.

Time Power Turned Off _____ Time Power Turned On _____

EXIT SIGNS

Exit Sign # Or Location	Bulbs Working Yes/No	90 Minute Test Pass/Fail	Parts Replaced Bulbs/Battery	Parts Receipts Yes/No

EMERGENCY LIGHT FIXTURES

Em. Light # Or Location	Bulbs Working Yes/No	90 Minute Test Pass/Fail	Parts Replaced Bulbs/Battery	Parts Receipts Yes/No

Business Name _____

Business Address _____

Date Test Performed _____ **By** _____